



Disinfection By-Products

Meeting the Challenge of Compliance with USEPA DBPR Stage 2

PA AWWA 64th Annual Conference
May 2-4, 2012

AUTHORS

T. Mike Sudman – City of Celina

Todd W. Hone – City of Celina

Cheryl L. Green – AECOM

PRESENTER

Stephanie Carr – Calgon Carbon Corporation

Chemviron Carbon

Presentation Outline

- Background
- Investigation of Alternatives
- Pilot Testing Program
- Full Scale Implementation
- Operating Data
- Treatment Costs
- Current Status



Granular Activated Carbon

Background

- The City of Celina, OH supplies drinking water to 11,647 residents
- Source water is *Grand Lake*, a 21 sq. mile water body
- *Grand Lake* contains high levels of total organic carbons (TOC) and supports a high concentration of Planktothrix algae

Background



Celina, Ohio



Grand Lake



Grand Lake / St Marys Watershed

Background

- Grand Lake watershed is primarily agricultural land
 - Lake itself is only 7' deep
- TOC concentrations average 12.5 mg/l and peak at over 20 mg/l
- Turbidity ranges from 10 to 300 NTU




← Image of water samples showing 5, 50, and 500 NTU turbidity

Background


- Celina water treatment consisted of:
 - Lime slaking
 - Upflow clarification
 - Recarbonation
 - Sand Filtration
 - Ozonation
 - Chlorination for residual disinfection
- In 1995, levels of disinfection by-products (DBPs) became an issue

Currently Regulated Disinfection By-Products

REGULATED CONTAMINANTS	Stage I MCL (mg/l)	Stage II MCL (mg/l)
TOTAL TRIHALOMETHANES (TTHM)	0.080 RAA	0.080 LRAA
Chloroform (CHCl_3)		
Bromodichloromethane (CHBrCl_2)		
Dibromochloromethane (CHBr_2Cl)		
Bromoform (CHBr_3)		
FIVE HALOACETIC ACIDS (HAA5)	0.060 RAA	0.060 LLRA
Monochloroacetic acid ($\text{C}_2\text{H}_3\text{ClO}_2$)		
Dichloroacetic acid (CHCl_2COOH)		
Trichloroacetic acid (CCl_3COOH)		
Bromoacetic acid ($\text{C}_2\text{H}_3\text{BrO}_2$)		
Dibromoacetic acid ($\text{C}_2\text{H}_2\text{Br}_2\text{O}_2$)		



Dichloroacetic Acid



Plus 1.0 mg/L for chlorite and 10 ug/L for bromate

Background

- Total trihalomethane (TTHM) four-quarter running average was found to be 221.5 $\mu\text{g/l}$
 - US and Ohio EPA limits are 80 $\mu\text{g/l}$
- May 31, 2003: Ohio EPA placed the city water facility under a Findings and Orders consent degree with a scheduled compliance date for TTHM of November 2007



Investigation of Alternatives

- It was determined that none of the City's existing treatment processes were effective in reducing TTHMs
 - In fact, the ozonation was suspected of breaking down the TOC into compounds which would more easily react with chlorine to form TTHMs



Ozone

- The City began a program to investigate alternative solutions

Investigation of Alternatives


- Initial alternatives explored in 2003-2004
 - Switch to groundwater
 - Unrealistic – Great Lakes Water Compact prohibits withdrawal of water from GL watershed for expulsion into another basin – City discharges into Gulf of Mexico watershed
 - Sulfur modified iron (SMI)
 - No appreciable effect
 - Conventional water clarification system
 - Reduced TOC 69%, but TTHM remained at 170 $\mu\text{g/l}$
 - Magnetic ion exchange (MIEX)
 - 38%-48% DOC removal, but TTHM remained above 100 $\mu\text{g/l}$ except when combined with chloramine as final disinfectant

Investigation of Alternatives

- In September 2004, City Council authorized an RFQ for facility improvements
- Floyd Browne and Metcalf & Eddy/AECOM were selected to lead the project
- Short list of treatment technologies was developed:
 - Switching to monochloramine disinfection
 - Installation of a reverse osmosis (RO) system
 - Installation of a granular activated carbon (GAC) system

Investigation of Alternatives


- Monochloramine addition was viewed as a potential short term solution
 - Technology was rejected due to:
 - concerns regarding formation of emerging DBPs (e.g. N-Nitrosodimethylamine, cyanogen chloride)
 - known effects of toxicity to marine life and potential nitrification in the distribution lines



Chloramine

Investigation of Alternatives

- Reverse Osmosis (RO) to remove organic DBP precursors was considered
 - Problems arose in the piloting effort
 - Issues centered on pretreatment of water to protect the RO membranes from fouling
 - The pretreatment problem proved complicated and time consuming
 - Given the high degree of urgency to meet the consent decree and the complexity of the pretreatment issues, RO was eliminated as a viable solution



Investigation of Alternatives

- Ultimately, granular activated carbon (GAC) technology was selected
 - Well known technology
 - Widely effective for a broad variety of drinking water sources
 - Piloting was simple and easily implemented



Pilot Testing Program


- A 3-phase pilot study was begun on December 13, 2005
 - Phase I: evaluated different GAC products
 - Phase II: simulated a two-vessel series system containing the selected GAC
 - Phase III: studied the operation of two vessels in a lead/lag staged bed operation
- Water plant operation was expanded to 3 shifts
- Calgon Carbon Corporation provided pilot columns and various grades of GAC for testing

Pilot Testing Program

- Individual pilot columns were filled to 4' depth with selected products
- These were run in various combinations to simulate beds with 8' media depths



Pilot Testing Program




Pilot Testing Results

- Series operation with staged replacement provided significant reduction in carbon usage over single bed operation
 - Staged Operation: spent GAC in lead vessel is exchanged with fresh GAC and valved to operated second in the series
- GAC adsorption could easily and consistently achieve targeted TOC level of 2.5 mg/l
- Projected annual operating cost (using virgin GAC only) was \$1.21/1,000 gal treated
 - Assumes influent TOC of 10 mg/l
 - This cost is higher than average municipal GAC systems, which typically range from \$0.15/1,000 gal to \$0.70/1,000 gal treated
 - Increase due to extraordinarily high influent TOC level present at Celina

Pilot Testing Results

- Bituminous coal based, agglomerated GAC was found to provide the best performance
 - Specific type selected: Calgon Carbon FILTRASORB 300



Full Scale Implementation

- Full scale system:
 - (8) x 40,000 lb. GAC pressure vessels
 - Operate in (4) parallel trains
 - Operate in staged sequence
 - Design flow rate: 520 gpm
 - Current actual flow rate: 240 gpm = 1.5 MGD for the entire system
 - At current flow, empty bed contact time (EBCT) = 78 minutes/vessel

Full Scale Implementation

- Full scale system:
 - At current flow, empty bed contact time (EBCT) = 78 minutes/vessel
 - 8 vessels, each holding 40,000 lbs. of GAC.
 - Assumed BWD density of 32 pcf.
 - GAC volume is therefore $40000/32 = 1,250$ cf
 - Vessels are arranged in (4) parallel trains.
 - Current flow rate is 240 gpm per train, per your note below.
 - (2) vessels in each train operate in parallel, so that the flow rate per vessel is 120 gpm
 - Therefore total system flow at this time equals $120 \text{ gpm} \times 8 = 960 \text{ gpm}$, which equals 1.38 MGD
 - $\text{EBCT} = (V \cdot C)/Q$, where V = GAC volume in cubic feet, Q = flow rate in gpm, and C = conversion factor of 7.48 gallons/cf
 - $\text{EBCT} = (1250 \cdot 7.48)/120 = 77.92$ minutes
 - $\text{EBCT (at design flow)} = (1250 \cdot 7.48)/260 = 36$ minutes

Full Scale Implementation




**Full scale Celina systems – (8) x 12' diameter,
40,000 lb capacity vessels**

Operating Data

- GAC system brought on-line July 2008
- System reduced finished water TOC to below 2.0 mg/l
- System reduced TTHM and HAA5 levels below the required levels of 80 $\mu\text{g/l}$ and 60 $\mu\text{g/l}$, respectively



Operating Data



Treatment Costs

- Total capital cost for project: \$7 million
 - Included: building, pumps, wet well, controls, lab, replacement intake structure, replacement sand filter valves, piloting, engineering, and the GAC system
- GAC system, including initial GAC fill, amounted to \$1.73 million



Treatment Costs

- Plant has switched to custom reactivated GAC (from virgin GAC)
 - Significant reduction in operating cost
 - No measurable reduction in performance
- Operating cost: \$384,000/year
 - \$0.35/1,000 gal treated based on installed capacity
 - Includes: reactivation of GAC, addition of make-up GAC, transportation, warehousing and services
- Estimated ten (10) year lifecycle cost
 - \$0.51/1,000 gal treated
 - Accounts for initial capital expenditure plus ongoing operating costs

Current Status

- Since start-up of the GAC systems, the expanded and improved WTP has produced an average of 1.5 MGD of drinking water, consistently measuring below the treatment goals for TTHMs and HAA5s
- As of Sept 30, 2009, the Findings and Orders decree has been lifted

Current Status

- If necessary, space exists for an additional four (4) GAC adsorbers
- At this point, GAC addition appears to have completely solved the issues associated with DBP compliance, while also significantly improving the taste, odor, and appearance of the Grand Lake water
- They are currently using custom reactivation service for the spent carbon





Thank You!

Questions?

