



# **Assessing Distribution System Integrity:** the case for maintaining a disinfectant residual

Mark W. LeChevallier, Ph.D.  
Director, Innovation & Environmental Stewardship

## Regulation of Disinfection in the US

- **Surface Water Treatment Rule**
  - Giardia and Virus CT values
  - Maintenance of disinfectant residual at 95% locations
- **Long Term II Enhanced Surface Water Treatment Rule**
  - Cryptosporidium
- **Groundwater Rule**
  - Viruses
- **Stage 1 Disinfection/Disinfection By-Product Rule**
  - maximum residual limit (based on an annual average) of 4 mg/L for free chlorine and chloramines
- **Total Coliform Rule**
  - Disinfectant residual monitoring locations



# Summary of State Regulations: Disinfectant Residuals

State	Distribution System Residual (mg/L)	Details about Monitoring, Compliance Determinations, etc.	Regulation Citations
EPA	SW – detectable residual or HPC ≤ 500	95% of samples. Detectable is not defined.	40 CFR § 141.72 (2015)
Alabama	0.2 (free), 0.5 (total)	Daily monitoring. If < 0.2 more than 4 hours, TT violation & PN within 14 days. If < 0.2 more than 24 hours, bacteria samples required. If positive, acute violation & PN.	Ala. Admin. Code r. 335-7-10-.04 (2014)
Colorado	0.2 (free or total)	Measured at TCR sites. Based on # samples - 95%, more than one, one.	5 Colo. Code Regs. § 1002-11, 11.8(3)(2015)
Delaware	0.3 (free)	Maintain throughout distribution system, daily monitoring at TCR sites, defines detectable as 0.04	16 Del. Admin. Code § 4462-8.2 (2015)
Florida	0.2 (free), 0.6 (total)	Maintain at all times. Two or five samples per week based on pop. If < min. residual, increase dose and flush until restored.	Fla. Admin. Code Ann. r. 62-555.350(6) (2015)
Georgia	0.2 (free)	Maintain in all locations.	Ga. Comp. R. & Regs. r. 391-3-5-.14(2) (2013)
Illinois	0.2 (free), 0.5 (total)	Maintain in all locations. Monitor at frequent and regular intervals.	Ill. Adm. Code tit. 35 § 653.604 (2015)
Indiana	0.2 (free), 0.5 (total)	Defines detectable as 0.2 free or 0.5 total. 95% of samples.	327 Ind. Admin. Code 8-2-1(98) (2015)
Iowa	0.3 (free), 1.5 (total)	Measured at TCR sites. Continuously maintained throughout DS except at dead ends. Defines detectable as 0.1.	Iowa Admin. Code r. 567-42.4(3) (2015)
Kansas	0.2 (free), 1.0 (total)	Daily monitoring. 95% of samples.	Kan. Admin. Regs. § 28-15-19 (2015)
Kentucky	0.2 (free), 0.5 (total)	Daily monitoring. Maintain throughout distribution system.	401 Ky. Admin. Regs. 8:150 (2015)
Louisiana	0.5 (free or total)	Daily at MRT sites, at TCR sample sites, and at 25% more sites.	La. Admin. Code. Tit 41, § 524, 525 (2015)
Minnesota	0.1 (free or total)	Requires a detectable residual and defines detectable as 0.1.	Minn. R. 4720.3965 (2015) & Minn. R. 4720.0450 (2015)
Missouri	0.2 (total)	Measured at TCR sites. 95% of samples.	Mo. Code. Regs. tit. 10 § 60-4.055(3)&(4) (2015)
Nebraska	SW - 0.2 (free), 0.25 or 0.5 (total); GW – 0.1 (free)	95% of samples.	179 Neb. Admin. Code 13-005.01D1 (2014)
Nevada	0.05 mg/L (free or total)	Requires a detectable residual and defines detectable as 0.05.	Nev. Admin. Code. § 445A.6683 (2014)
New Jersey	0.05 mg/L (free or total)	Requires a detectable residual and defines detectable as 0.05.	N.J. Admin. Code § 7:10-11.16 & 7:10-1.3 (2015)
North Carolina	0.2 (free), 1.0 (total)	Measured at TCR sites. Must be detectable at MRT sites.	15 N.C. Admin. Code 18C.2002 (2015)
Ohio	0.2 (free), 1.0 (total)	Measured at TCR sites. 95% of samples.	Ohio Admin. Code 3745-81-72 & 3745-83-01 (2015)
Oklahoma	0.2 (free), 1.0 (total)	Maintain at most distant points.	Okla. Admin. Code § 252:631-3-3 (2014)
Pennsylvania	Proposed: 0.20 mg/L (free or total)	Proposed: 95% of samples, monitor daily or weekly, 5% OOC cannot be repeated.	25 Pa. Code. § 109.710 & 109.301 (2015)
Tennessee	0.2 (free)	Monitor at TCR sites. 95% of samples.	Tenn. Comp. R. & Regs. 0400-45-01-.31 & .17 (2015)
Texas	0.2 (free), 0.5 (total)	Daily or weekly monitoring based on pop. 95% of samples.	30 Tex. Admin. Code § 290.110 (2015)
Vermont	0.1 (free)	Maintain at distant points and defines detectable as 0.1.	12-030-003 Vt. Code. R. 21 (2015)
West Virginia	0.2 (total)	Minimum at all points.	64CSR77, 6.4.c

# Water Treatment: the Multiple Barrier Concept

- **Source Water Protection**

Surface Water

Groundwater

- **Filtration**


- **Disinfection**

- **Distribution System**

Chlorine residual


Pressurized networks

Cross connection  
control



*Cryptosporidium  
parvum*

© James A. Sullivan  
Quill Graphics  
Charlottesville, VA USA



# Dead-End Free Chlorine Residual

Residual mg/L	N	#Samples	# Positive	# Colonies	% Positive	Avg/100 mL
0 - 0.2	99	11,056	138	10,535	1.248	0.953
0.2 - 0.5	159	10,637	36	2,850	0.338	0.267
0.5 - 1.0	164	14,276	87	2,107	0.609	0.147
> 1.0	127	7,803	118	4,955	1.512	0.635

# Dead-End Chloramine Residual

Residual mg/L	N	#Samples	# Positive	# Colonies	% Positive	Avg/100 mL
0 - 0.5	110	11,447	67	331	0.585	0.029
0.5 - 1.0	125	7,106	20	66	0.281	0.009
1.0 - 2.0	121	7,564	13	15	0.171	0.001
> 2.0	105	9,835	83	213	0.844	0.022


## Relationship between Disinfection and AOC on Coliform Occurrences

<b>System</b>	<b>AOC Level (ug/L)</b>	<b>% Samples Positive</b>	<b>Avg. Coliform /100 mL</b>
Free Chlorinated	120 - 189	1.24	1.077
Systems, N=11	50 - 93	0.68	0.058
Chloraminated	101 - 166	0.87	0.022
Systems, N=11	42 - 99	0.36	0.015

Free chlorinated systems with high AOC had 87% higher occurrence rate, and bacterial levels 19 times higher than low AOC systems.

Chloraminated systems with high or low AOC were not statistically different.

# Impact of Pipe Surface on Disinfection of Biofilm Bacteria



LeChevallier, Lowry, and Lee. 1990. *J. Amer. Water Works Assoc.* 82(7): 87-99.






# Model for Monochloramine Disinfection of Biofilm Bacteria

	Coefficient	Standard Error	t-Statistic	Significance Level
Log reduction viable counts=				
Intercept	-1.0734	0.5685	-1.888	0.0816
Log Larson Index	-0.5808	0.1963	-2.958	0.0111
Log Corrosion Rate	-0.4820	0.3205	-1.504	0.1566
Log Monochloramine	2.0086	0.9226	2.177	0.0485
Phosphate Level	0.1445	0.0336	4.295	0.0009
Corrected R-Squared:	0.746	F test:	13.474	

Model is based on 18 observations






# Model for Free Chlorine Disinfection of Biofilm Bacteria

	Coefficient	Standard Error	t-Statistic	Significance Level
Log reduction viable counts =				
Intercept	-2.7770	0.9036	-3.073	0.0083
Phosphate Level	-0.0889	0.0444	-2.001	0.0651
Natural Log Corrosion	1.1015	0.4803	2.294	0.0378
Exp. Larson Index	1.1971	0.4917	2.435	0.0289
Exp. Corrosion Rate	4.1647	0.9991	4.168	0.0009
Corrected R-Squared:	0.742	F Test:	13.930	

Model is based on 19 observations



# Nosocomial Legionnaires' Disease

## **Kool et al., *Lancet* 353: 272-277 1999**

- Examined 32 nosocomial outbreaks, 1979-1997, in which drinking water was implicated
  - ◆ Examined characteristics of the hospital (size, transplant program), primary disinfectant treatment, disinfectant residual, water source, community size, pH.
- Odds of nosocomial outbreak was 10.2 (1.4-460) higher in systems that maintained free chlorine versus a chloramine residual.
- Estimated that 90% of outbreaks could be prevented if chloramines were universally used.

## Nosocomial Legionnaires' Disease

### International Conference on Nosocomial Infections ([www.decennial.org](http://www.decennial.org)):

- ✓ Survey 166 hospitals. Those supplied with chloraminated water were less likely (RR=0.36, CI=0.18-0.72) to have nosocomial Legionnaires disease.

### International Legionella Conference ([www.uni-ulm.de](http://www.uni-ulm.de)):

- ✓ Monochloramine at 1.5 mg/L resulted in >99.9% inactivation of Legionella biofilms within 60 min.

### Association for Professionals in Infectious Control ([www.apic.org](http://www.apic.org)):


- ✓ Fed chloramines to a hospital. Legionella were 97.9 cfu/mL before (n=72), and 0.13 cfu/mL after (n=104) treatment with 0.1 mg/L chloramines.

## Lessons from Real Life: San Francisco, CA

- 53 buildings
- Sampled 3 times pre- and post-conversion to chloramines
- Sampled hot water heater and four distal sites
- Sampled swab and water from distal sites
- Surveys collected data on building age, height, type and number of hot water heaters
- pH, temperature, free or total Cl<sub>2</sub> residual measured for each sample


Flannery, B. et al. 2006. Reducing *Legionella* colonization of water systems with monochloramine. *Emerg. Infect. Dis.* 12(4): 588-596.

<http://www.cdc.gov/ncidod/EID/vol12no04/05-1101.htm>.



## Legionella and Amoebae

- Intracellular *Legionella* in: *Acanthamoeba*, *Amoeba*, *Comandonia*, *Echinamoeba*, *Filamoeba*, *Hartmannella*, *Naegleria*, *Paratetramitus*, *Vahlkamfia*, *Tetrahymena*, *Dictyostelium*
- *Legionella* survive for months, resistant to 50 mg/L free chlorine for 18 hr
- Coated with amoebal proteins
- Increases virulence, replication
- *Legionella*-containing vacuoles expelled prior to encystation
- Trophozoite stage sensitive to disinfectants ( $CT_{99.9} = 1.5 \text{ mg-min/L}$ )



Trophozoite




Cyst





# Trophozoite Concentration




  
**Chloramines**

Legionella in Biofilm




Low Risk?  
Growth Limited?  
Virulence genes not induced

Free Living Trophozoites



High Risk?  
Amplification in amoebae  
Virulence genes induced

Stressor - Disinfectant  
Low Nutrients  
Other Stress



Low Risk  
No growth in cysts  
Legionella die off


## Disinfection – *M avium*

Calculated disinfection  $CT_{99.9\%}$  (mg·min/l) for *E. coli* and *M. avium* strains\*

Disinfectant Condition	Control	<i>Mycobacterium avium</i> Strain				
	<i>E. coli</i>	A5	1060	1508	5002	5502
Chlorine (M7H9)	0.088 ± 0.003	106 ± 9	204 ± 36	164 ± 28	126 ± 27	51 ± 10
Chlorine (water)	Not Done	1552 ± 403	1445 ± 238	596 ± 292	962 ± 431	551 ± 290
Monochloramine	73 ± 28	97 ± 9	458 ± 152	548 ± 62	1710 ± 814	91 ± 34
Chlorine Dioxide	0.015 ± 0.003	Not Done	8 ± 3	Not Done	11 ± 2	2 ± 0.1
Ozone	0.002 ± 0.002	Not Done	0.17 ± 0.14	Not Done	0.12 ± 0.01	0.10 ± 0.01

\* Cells were exposed to the disinfectants in demand-free phosphate buffer (pH 7.0) at 23 °C  
Taylor et al., 2000, *Appl. Environ. Microbiol.* 66(4): 1702-1705.

# Mycobacterium Disinfection by Free Chlorine



Experimental conditions: pH 7.0, 25°C, initial free chlorine concentration 0.5 mg/l. Adapted from Le Dantec *et al.* 2002.

## Impact of nutrient level, disinfectant, and pipe material on *M. avium* and HPC levels










AOC Level	Disinfectant Type	Disinfectant Residual (mg/l)	Copper Pipe <sup>1</sup>		Iron Pipe <sup>1</sup>	
			HPC	<i>M. avium</i>	HPC	<i>M. avium</i>
85 µg/l AOC	Free chlorine	0.6	1.76	0.18	6.02	5.85
	Chloramine	2.2	2.44	2.38	5.21	4.92
213 µg/l AOC	Free chlorine	0.3	2.17	0.37	5.93	5.50*
	Chloramine	1.4	2.43	2.10	5.89	5.20*

<sup>1</sup> Values are log CFU/cm<sup>2</sup>, \* Corrosion products interfered with these analyses


Norton, LeChevallier, and Falkinham. 2004. *Water Research*, **38**: 1457-1466.

# Development of QMRA


1. External virus concentration
2. Negative pressure duration
3. Intrusion volume
4. Dilution
5. Virus Transport
6. Population Exposed
7. Coincidence of exposure
8. Volume consumed
9. Dose Response
10. Risk Calculation



# Virus transport without a disinfectant residual



## Minimum Disinfectant Residual



Free chlorine residuals >0.2 mg/L eliminated Norovirus virus risk due to intrusion of 0.1% wastewater




## Disinfectant Residual Performance Assessment

### Performance Goals:

- Chlorine residual 95% > 0.2mg/L free chlorine or > 0.5 mg/L total chlorine (chloramine systems)
- Chlorine residual may not be undetectable for two consecutive months
- Monitoring based on a representative system wide plan consisting of key sites and compliance sites:
  - Stage 1 & 2 DBP sites, TCR and tank sites and all pressure zones
  - The minimum number of sites should be population based
  - Monthly minimum monitoring
  - Sample taps flushed to be representative of water in the main
  - Testing conducted using colorimeter or online monitor


# Disinfectant Residual Monitoring: example



Meets 95% >0.2 mg/L free chlorine, but not 2 consecutive months >0

## Accuracy of Disinfectant Residual Measurement

- Important to consider measurement variation
- If the true target is 0.2 mg/L, and measurements have 0.1 mg/L variation, then utilities must maintain 0.3 mg/L to ensure compliance
- Most systems will utilize an 80% safety factor
- Therefore a regulation for 0.1 mg/L will result in a true residual of 0.2-0.3 mg/L for compliance



# Strategy For Managing Distribution System Integrity

## Chloraminated Systems

- **Control Intrusion**
  - Pressure Management
  - Leak Detection
  - Main Break/Repair
  - Sewer Separation/Leakage
- **Nitrification Control**
  - Control Water Age
- **Cross Connection Control**
- **Corrosion Control/Material Compatibility**
- **Maintain Storage Facilities**
- **Security**



## Free Chlorinated Systems

- **Control Biofilms**
  - Organic Carbon Control
  - Measure/Reduce AOC
  - Disinfectant Residuals
  - Biological Treatment
- **DBP Control**
  - Control Water Age
- **Cross Connection Control**
- **Corrosion Control/Material Compatibility**
- **Maintain Storage Facilities**
- **Security**

# WE CARE ABOUT WATER. IT'S WHAT WE DO.

## Contact Information:

Mark W. LeChevallier, Ph.D.  
Vice President, Chief Environmental Officer  
Stewardship  
American Water  
1025 Laurel Oak Road  
Voorhees, NJ 08043 USA  
phone: (856) 727-6106  
fax: (856) 727-6199  
e-mail: [mark.lechevallier@amwater.com](mailto:mark.lechevallier@amwater.com)

**AWK**  
**LISTED**  
**NYSE.**