

CREATING A CAPITAL PLAN USING MST AND THE NASSCO PIPELINE ASSESSMENT PROGRAM

– Michael A. Schober, PE, BCEE
T&M Associates



AGENDA

1

Overview of Multi-Sensor Technology (MST)

2

Project Description

3


NASSCO Pipe Line Assessment Program

4

Creating a Capital Plan




OVERVIEW OF MULTI-SENSOR TECHNOLOGY



CCTV

High Resolution with
Pan & Tilt Capabilities



LASER

Detects Corrosion
and Deformation




SONAR

Detects Debris and
Deformation


MULTI-SENSOR TECHNOLOGY REPORTING

Debris Graphs




MULTI-SENSOR TECHNOLOGY REPORTING

Flat Graphs



MULTI-SENSOR TECHNOLOGY REPORTING

Cross Sections



Debris to 13.7"

MULTI-SENSOR TECHNOLOGY REPORTING


Line Report

Profile/Photo Observation Report

Date:	06/25/2017	Weather:	Dry	Coding:	PACP 4.2
Pipe Length (ft):	440.2	Owner:	WVSA	Pre Clean:	No Pre-Cleaning
P.O.#:		Surveyor:	Jen Costello	PSR:	I-7_I-6
Customer:		Clean Date:		Shape:	C
Street:	Levee Easement	Flow Control:	Not Controlled		
City:		Year Renewed:			
Location:	Other	Tape/Media #:			
Purpose:	Routine Assessment	Dia/Height:	78"		
Use:	Sanitary	Material:	RCP		
Drain Area:		Lining:			
Category:	NA				
Comment:					
Location Details:		Direction of Survey:	Downstream		
US MH:	I-7	DS MH:	I-6	Total Length Surveyed (ft):	440.2
O&M Index:	1.00	O&M Quick:	1N00	O&M Rating:	76
Structural Index:	2.98	Structural Quick:	3P22	Structural Rating:	262
Overall Index:	2.06	Overall Quick:	3P22	Overall Rating:	338

MULTI-SENSOR TECHNOLOGY REPORTING

Line Report




OVERVIEW OF INTERCEPTOR



OVERVIEW OF INTERCEPTOR

1. Constructed in late 1960's
2. Just over 5 Miles
3. Size Range 30" to 84"
4. Constructed of Reinforced Concrete Pipe



NASSCO PIPELINE ASSESSMENT PROGRAM

A Typical Report Summary will consist of a Database which includes this information:

- Pipe ID
- MH ID
- Diameter
- Length
- Water Depth
- Debris Depth
- Debris Volume
- Corrosion
- Structural Quick Score
- OM Quick Score

NASSCO PIPELINE ASSESSMENT PROGRAM



NASSCO PIPELINE ASSESSMENT PROGRAM

A Typical Report Summary will consist of a Database which includes this information:

- Pipe ID
- MH ID
- Diameter
- Length
- Water Depth
- Debris Depth
- Debris Volume
- Corrosion
- Structural Quick Score
- OM Quick Score

NASSCO PIPELINE ASSESSMENT PROGRAM

A Typical Report Summary will consist of a Database which includes this information:

Pipe and Inspection Information							Sonar Data				Laser Data	
Pipe ID	Upstream MH	Dnstream MH	Pipe Height /Diam (in)	Structural Score	OM	Length Surveyed	Water Depth (in)	Max Debris Depth (Inches)	Avg. Debris Depth (Inches)	Debris Volume (cu. Ft)	Avg. Corrosion (in)	Max. Corrosion (In)
I-48 I-47	I-48	I-47	30	5A35	0000	94	16.8	2.9	0.1	0.5	0.1	0.8
I-47 I-46	I-47	I-46	30	543P	211J	422.7	11	0	0	0	0.1	1.1
I-46 I-45	I-46	I-45	30	3H00	2300	231.6	14.2	0	0	0	0	0.8
I-45 I-44	I-45	I-44	30	5X35	0000	649.4	8.5	0	0	0	0.2	2.2
I-44 I-43	I-44	I-43	30	5800	0000	94.2	9.4	0	0	0	0.6	2
I-43 I-42	I-43	I-42	30	5032	251K	411	14.9	0	0	0	0.3	1.5
I-42 I-41A	I-42	I-41A	30	5A3D	0000	179.7	13.4	0	0	0	0.6	1.4
I-41A I-41	I-41A	I-41	30	3100	4100	14.1	0	0	0	0	0	2.3
I-41 I-40A	I-41	I-40A	30	553E	0000	154.7	12.4	0	0	0	0.3	1
I-40A I-40	I-40A	I-40	30	3100	0000	9.1	0	0	0	0	0	0
I-40 I-39A DS	I-40	I-39A	30	5637	0000	35.5	6.6	0	0	0	0.3	2.1
I-40 I-39A US	I-40	I-39A	30	5637	0000	35.5	6.7	0	0	0	0.5	1.9
I-39A I-39	I-39A	I-39	30	3000	0000	416.3	13.3	4.2	0.2	2.5	0.2	0.7
I-39 I-38	I-39	I-38	30	3E00	2111	157	12	3.2	0.5	4.9	0.1	1.9
I-38 JC-4	I-38	JC-4	30	3200	4100	6	10.8	0	0	0	0	0.3
JC-4 I-37	JC-4	I-37	48	5533	3214	509.4	25.1	7.8	1.1	69.3	0.6	2.9

NASSCO PIPELINE ASSESSMENT PROGRAM

Pipe and Inspection Information						
Pipe ID	Upstream MH	Dnstream MH	Pipe Height /Diam (in)	Structural Score	OM	Length Surveyed
I-48 I-47	I-48	I-47	30	5A35	0000	94
I-47 I-46	I-47	I-46	30	543P	211J	422.7
I-46 I-45	I-46	I-45	30	3H00	2300	231.6
I-45 I-44	I-45	I-44	30	5X35	0000	649.4
I-44 I-43	I-44	I-43	30	5B00	0000	94.2
I-43 I-42	I-43	I-42	30	5O32	251K	411
I-42 I-41A	I-42	I-41A	30	5A3D	0000	179.7
I-41A I-41	I-41A	I-41	30	3100	4100	14.1
I-41 I-40A	I-41	I-40A	30	553E	0000	154.7
I-40A I-40	I-40A	I-40	30	3100	0000	9.1
I-40 I-39A DS	I-40	I-39A	30	5637	0000	35.5
I-40 I-39A US	I-40	I-39A	30	5637	0000	35.5
I-39A I-39	I-39A	I-39	30	3O00	0000	416.3
I-39 I-38	I-39	I-38	30	3E00	2111	157
I-38 JC-4	I-38	JC-4	30	3200	4100	6
JC-4 I-37	JC-4	I-37	48	5S33	3214	509.4

Data
Max. Corrosion (In)
0.8
1.1
0.8
2.2
2
1.5
1.4
2.3
1
0
2.1
1.9
0.7
1.9
0.3
2.9



NASSCO PIPELINE ASSESSMENT PROGRAM

Pipe and			Sonar Data				Laser Data		
Pipe ID	Upstream MH	Dnstream M	Water Depth (in)	Max Debris Depth (Inches)	Avg. Debris Depth (Inches)	Debris Volume (cu. Ft)	Debris Volume (cu. Ft)	Avg. Corrosion (in)	Max. Corrosion (in)
I-48 I-47	I-48	I-47	16.8	2.9	0.1	0.5	0.5	0.1	0.8
I-47 I-46	I-47	I-46	11	0	0	0	0	0.1	1.1
I-46 I-45	I-46	I-45	14.2	0	0	0	0	0	0.8
I-45 I-44	I-45	I-44	8.5	0	0	0	0	0.2	2.2
I-44 I-43	I-44	I-43	9.4	0	0	0	0	0.6	2
I-43 I-42	I-43	I-42	14.9	0	0	0	0	0.3	1.5
I-42 I-41A	I-42	I-41A	13.4	0	0	0	0	0.6	1.4
I-41A I-41	I-41A	I-41	0	0	0	0	0	0	2.3
I-41 I-40A	I-41	I-40A	12.4	0	0	0	0	0.3	1
I-40A I-40	I-40A	I-40	0	0	0	0	0	0	0
I-40 I-39A DS	I-40	I-39A	6.6	0	0	0	0	0.3	2.1
I-40 I-39A US	I-40	I-39A	6.7	0	0	0	0	0.5	1.9
I-39A I-39	I-39A	I-39	6.7	0	0	0	2.5	0.2	0.7
I-39 I-38	I-39	I-38	13.3	4.2	0.2	2.5	4.9	0.1	1.9
I-38 JC-4	I-38	JC-4	12	3.2	0.5	4.9	0	0	0.3
JC-4 I-37	JC-4	I-37	10.8	0	0	0	69.3	0.6	2.9
			25.1	7.8	1.1	69.3			

NASSCO PIPELINE ASSESSMENT PROGRAM

Pipe and Inspection Information				Laser Data	
Pipe ID	Upstream MH	Downstream MH	Pipe Height / Diam (in)	Avg. Corrosion (in)	Max. Corrosion (in)
I-48 I-47	I-48	I-47	30	0.1	0.8
I-47 I-46	I-47	I-46	30	0.1	1.1
I-46 I-45	I-46	I-45	30	0	0.8
I-45 I-44	I-45	I-44	30	0.2	2.2
I-44 I-43	I-44	I-43	30	0.6	2
I-43 I-42	I-43	I-42	30	0.3	1.5
I-42 I-41A	I-42	I-41A	30	0.6	1.4
I-41A I-41	I-41A	I-41	30	0	2.3
I-41 I-40A	I-41	I-40A	30	0.3	1
I-40A I-40	I-40A	I-40	30	0	0
I-40 I-39A DS	I-40	I-39A	30	0	0
I-40 I-39A US	I-40	I-39A	30	0.3	2.1
I-39A I-39	I-39A	I-39	30	0.3	2.1
I-39 I-38	I-39	I-38	30	0.5	1.9
I-38 JC-4	I-38	JC-4	30	0.2	0.7
JC-4 I-37	JC-4	I-37	48	0.2	0.7
				0.1	1.9
				0	0.3
				0.6	2.9

Sonar Data			Laser Data	
Max Debris Depth (Inches)	Avg. Debris Depth (Inches)	Debris Volume (cu. Ft)	Avg. Corrosion (in)	Max. Corrosion (in)
2.9	0.1	0.5	0.1	0.8
0	0	0	0.1	1.1
0	0	0	0	0.8
0	0	0	0.2	2.2
0	0	0	0.6	2
0	0	0	0.3	1.5
0	0	0	0.6	1.4
0	0	0	0	2.3
0	0	0	0.3	1
0	0	0	0	0
0	0	0	0.3	2.1
0	0	0	0.5	1.9
4.2	0.2	2.5	0.2	0.7
3.2	0.5	4.9	0.1	1.9
0	0	0	0	0.3
7.8	1.1	69.3	0.6	2.9

NASSCO PIPELINE ASSESSMENT PROGRAM

A Typical Report Summary will consist of a Database which includes this information:


- Pipe ID
- MH ID
- Diameter
- Length
- Water Depth
- Debris Depth
- Debris Volume
- Corrosion
- Structural Quick Score
- OM Quick Score

NASSCO PIPELINE ASSESSMENT PROGRAM

PACP Grading System

Grade 5	Immediate	Pipe has failed or will likely fail.
Grade 4	5-10 Years	Pipe has severe defects.
Grade 3	10-20 Years	Pipe has moderate defects.
Grade 2	20-30 years	Pipe has minor defects.
Grade 1	30+ Years	Pipe has minor defects.

STRUCTURAL QUICK SCORE



NASSCO PIPELINE ASSESSMENT PROGRAM

Pipe and Inspection Information							
Pipe ID	Upstream MH	Dnstream MH	Pipe Height /Diam (in)	Structural Score	OM	Length Surveyed	
I-48 I-47	I-48	I-47	30	5A35	0000	94	
I-47 I-46	I-47	I-46	30	543P	211J	422.7	
I-46 I-45	I-46	I-45	30	3H00	2300	231.6	ata
I-45 I-44	I-45	I-44	30	5X35	0000	649.4	Max. Corrosion (in)
I-44 I-43	I-44	I-43	30	5B00	0000	94.2	0.8
I-43 I-42	I-43	I-42	30	5O32	251K	411	1.1
I-42 I-41A	I-42	I-41A	30	5A3D	0000	179.7	0.8
I-41A I-41	I-41A	I-41	30	3100	4100	14.1	2.2
I-41 I-40A	I-41	I-40A	30	553E	0000	154.7	2
I-40A I-40	I-40A	I-40	30	3100	0000	9.1	1.5
I-40 I-39A DS	I-40	I-39A	30	5637	0000	35.5	1.4
I-40 I-39A US	I-40	I-39A	30	5637	0000	35.5	2.3
I-39A I-39	I-39A	I-39	30	3O00	0000	416.3	1
I-39 I-38	I-39	I-38	30	3E00	2111	157	0
I-38 JC-4	I-38	JC-4	30	3200	4100	6	2.1
JC-4 I-37	JC-4	I-37	48	5S33	3214	509.4	1.9

PIPELINE CONDITION SUMMARY

Pipe and Inspection Information							Sonar Data				Laser Data	
Pipe ID	Upstream MH	Downstream MH	Pipe Height /Diam (in)	Structural Score	OM	Length Surveyed	Water Depth (in)	Max Debris Depth (Inches)	Avg. Debris Depth (Inches)	Debris Volume (cu. Ft)	Avg. Corrosion (in)	Max. Corrosion (in)
I-48 I-47	I-48	I-47	30	5A35	0000	80	16.8	2.9	0.1	0.5	0.1	0.8
I-47 I-46	I-47	I-46	30	5A3P	2111	400	11	0	0	0	0.1	1.1
I-46 I-45	I-46	I-45	30	3100	2300	250	14.2	0	0	0	0	0.8
I-45 I-44	I-45	I-44	30	5A35	0000	650	8.5	0	0	0	0.2	2.2
I-44 I-43	I-44	I-43	30	5B00	0000	100	9.4	0	0	0	0.6	2
I-43 I-42	I-43	I-42	30	5032	251K	420	14.9	0	0	0	0.3	1.5
I-42 I-41A	I-42	I-41A	30	5A3D	0000	200	13.4	0	0	0	0.6	1.4
I-41A I-41	I-41A	I-41	30	3100	4100	50	0	0	0	0	0	2.3
I-41 I-40A	I-41	I-40A	30	5558	0000	125	12.4	0	0	0	0.3	1
I-40A I-40	I-40A	I-40	30	3100	0000	15	0	0	0	0	0	0
I-40 I-39A DS	I-40	I-39A	30	5637	0000	40	6.6	0	0	0	0.3	2.1
I-40 I-39A US	I-40	I-39A	30	5637	0000	40	6.7	0	0	0	0.5	1.9
I-39A I-39	I-39A	I-39	30	3000	0000	400	13.3	4.2	0.2	2.5	0.2	0.7
I-39 I-38	I-39	I-38	30	3100	2111	150	12	3.2	0.5	4.9	0.1	1.9
I-38 IC-4	I-38	IC-4	30	5200	4100	10	10.8	0	0	0	0	0.3
IC-4 I-37	IC-4	I-37	48	5551	321A	500	25.1	7.8	1.1	69.3	0.6	2.9
I-37 I-36	I-37	I-36	48	5F31	1100	150	26	3.6	0.4	6.2	0.6	1.6
I-36 I-35	I-36	I-35	48	5C00	1500	150	25.4	3	0.3	2.6	0.5	1.8
I-35 I-34	I-35	I-34	60	5D3U	1X00	600	29	18.5	6.2	806	0.2	2.8
I-34 I-33A	I-34	I-33A	60	3P00	211P	400	30.5	7.3	4.9	346.5	0.3	1.9
I-33A I-33	I-33A	I-33	60	3000	1100	200	28.3	13.7	6.7	274.2	0.3	1.7
I-33 I-32	I-33	I-32	60	3A00	1300	50	28.6	6.3	1.6	8.3	0.1	2.3
I-32 I-31	I-32	I-31	7	5A00	1100	30	MSI Data Missing					
I-31 I-30	I-31	I-30	72	3200	0000	80	32.5	9.2	4.5	7.5	0	1.6
I-30 I-29	I-30	I-29	72	3200	1X00	500	35.6	26.1	15.1	3669.9	0	0.2
I-29 I-28	I-29	I-28	72	0000	1100	600	25.5	8.1	0.4	21.3	0.3	1.3
I-28 Val-1	I-28	Val-1	72	3600	1100	500	24.8	7	1.00	177.6	0.2	0.7
Val-1 I-25	Val-1	I-25	72	3500	0000	450	31.7	17	6.1	825.6	0	0.4
I-25 I-24	I-25	I-24	72	3P00	0000	460	36.3	19.7	14.4	1755.6	0	0.5
I-24 I-23	I-24	I-23	72	3000	0000	120	24.7	0.4	0.1	0.1	0.2	0.5
I-23 I-23	I-23	I-23	72	5131	0000	225	33.3	10.8	6.2	431.8	0.4	0.9
I-23 I-19	I-23	I-19	72	3221	0000	1000	29.5	19.8	8.6	2404.4	0.1	1.1
I-19 I-21	I-19	I-21	72	3200	211K	800	37.1	19.2	11.2	2402.3	0.1	10.6
I-21 I-20	I-21	I-20	72	3700	0000	50	28.9	7.8	5.8	36.7	0.3	1.2
I-20 I-18 DS	I-20	I-18	72	3100	0000	250	29.8	6.9	2	161.9	0.1	0.4
I-20 I-18 US	I-20	I-18	72	3100	0000	325	25.7	4.8	0.9	21.6	0.1	0.4
I-18 I-17	I-18	I-17	72	3100	0000	600	30.9	11.6	5.7	642.4	0	0.8
I-17 I-16	I-17	I-16	72	3100	2111	500	29.7	7.5	0.9	79.5	0.3	2.5
I-16 I-15A	I-16	I-15A	72	3000	1100	500	30.1	0.4	0	0.5	0.1	1.6
I-15A I-15	I-15A	I-15	72	3000	1N00	400	31.2	2.9	0	1.1	0.2	0.9
I-15 I-14	I-15	I-14	72	3022	1100	625	32	8.6	0.3	29.9	0.3	1
I-14 I-13A	I-14	I-13A	72	3121	0000	500	34.8	5.4	0.2	7.4	0.1	0.5
I-13A I-13	I-13A	I-13	72	3000	0000	275	36.4	7.1	0.5	21.3	0.3	0.7
I-13 I-12	I-13	I-12	72	3000	100	100	31.6	1.3	0.5	0.5	0.2	0.7
I-12 I-11	I-12	I-11	72	3A00	1N00	600	33.6	0.8	0.1	2.1	0.1	0.8
I-11 I-10	I-11	I-10	72	3U00	0000	550	33.7	5.4	0.1	3.8	0.2	0.8
I-10 I-9	I-10	I-9	72	3500	0000	500	36	9.8	0.3	17	0.2	0.8
I-9 I-8	I-9	I-8	72	3V21	1100	550	35.9	3	0.2	4.8	0.1	0.6
I-8 I-7	I-8	I-7	72	3100	1N00	500	36.3	9.8	0.5	30.9	0	0.7
I-7 I-6	I-7	I-6	72	3P22	1N00	450	34.5	8.7	0.7	44.1	0.1	0.7
I-6 I-5	I-6	I-5	72	3P22	1V00	650	34.6	2.8	0.2	6	0.2	0.8
I-5 I-4	I-5	I-4	72	3P00	1100	650	38.9	7	0.4	21.9	0.1	0.6
I-4 I-3	I-4	I-3	72	3221	0000	750	32.4	1.2	0.1	3.8	0.2	1.8
I-3 DC-1	I-3	DC-1	72	3200	0000	1200	30.5	0.5	0	0.5	0	0.5
DC-1 I-2	DC-1	I-2	78	5131	2100	450	32	2.2	0.1	1.6	0.3	1.8
I-2 I-1	I-2	I-1	78	5131	1200	550	35	8.7	0.4	21.1	0	0.5
I-1 I-0	I-1	I-0	78	5B31	1R00	500	35.7	4.4	0.4	13.6	0	0.7
I-0 I-00	I-0	I-00	78	513V	1500	650	40.2	4.7	0.5	25.1	0	8
I-00 I-000	I-00	I-000	84	5C41	1100	150	40.3	1.3	0.2	1	0.1	0.7
I-000 Wet Well	I-000	Wet Well	84	3900	0000	75	40	2.1	0.3	0.6	0	0.5
III-6 III-5	III-6	III-5	36	3000	30	21.7	11.2	11.2	465.3	0	0.1	0.4
III-5 III-4	III-5	III-4	36	3900	31.21	500	21.5	14.5	9.8	756.7	0	0.3
III-4 III-3A	III-4	III-3A	36	5C00	1100	150	21.7	11.8	10.1	225.6	0	0.4
III-3A III-3	III-3A	III-3	36	4130	1P00	475	19.6	11.8	7.3	482.5	0.1	0.4
III-3 III-2	III-3	III-2	36	0000	1100	400	17.3	5.2	1.6	52.4	0	0.1
III-2 III-1	III-2	III-1	36	3D00	1000	150	21.3	10.2	3.9	62.9	0	0.3
III-1 III-OP	III-1	III-OP	36	5C00	III-OP	21.8	21.8	7.4	1.5	32.1	0	0.4
III-OP I-00	III-OP	I-00	72	3A00	0000	400	25.5	22.2	12	1197.2	0.1	0.5

CAPITAL PLANNING

Severity Grade	No. of Pipe Segments	Total Feet
5	20	6,010
4	1	475
3	45	17,635
2	0	0
1	2	1,000

CAPITAL PLANNING

Severity Grade	Pipe Diameter	Feet	Cost Per Foot		Total Cost	
			Low	High	Low	High
5	30	2,055	\$200	\$350	\$411,000	\$719,000
	48	800	\$400	\$500	\$320,000	\$400,000
	60	630	\$600	\$750	\$378,000	\$473,000
	72	225	\$750	\$1,000	\$169,000	\$225,000
	78	2,150	\$850	\$1,200	\$1,828,000	\$2,580,000
	84	150	\$900	\$1,400	\$135,000	\$210,000
To be rehabilitated in 0 to 5 years					\$3,241,000	\$4,607,000
3	30	875	\$200	\$350	\$175,000	\$306,000
	36	1,200	\$300	\$400	\$360,000	\$480,000
	60	650	\$600	\$750	\$390,000	\$488,000
	72	14,835	\$750	\$1,000	\$11,126,000	\$14,835,000
	84	75	\$900	\$1,400	\$68,000	\$105,000
To be rehabilitated in 10 to 20 years					\$12,119,000	\$16,214,000

SUMMARY

- 1 Use Technology to more efficiently to inspect large diameter sewers.
- 2 Use Industry Standards to assess pipeline conditions.
- 3 Develop a long-term capital and financing plan to accomplish your goals.

QUESTIONS

Presenter

Michael Schober, PE, BCEE

Regional Client Service Manager


T&M Associates

mschober@tandmassociates.com | 717.781.8709



SOUTH MONMOUTH REGIONAL SEWERAGE AUTHORITY

(SMRSA)



SERVES 8 MUNICIPALITIES

MAJOR ASSETS

- 9.1 MGD Wastewater Treatment Plant
- 11 pump stations
- 12 miles of force main

CLIMATE DRIVES PROJECTS

Three Major Storm Events

SMRSA's Cost of Rehabilitation after:

2009 NOR'EASTER

\$1.8 Million

2011 HURRICANE IRENE

\$2.5 Million

2012 SUPERSTORM SANDY

\$1.8 Million

CLIMATE RELATED CHALLENGES



SPRING LAKE'S PENNSYLVANIA AVENUE PUMP
STATION | SANDY, DAY 8




LAKE COMO PUMP STATION | SUPER STORM SANDY

Impacts of extreme wet weather events:


- Temporary loss in Sanitary Sewer Service
- Damage to assets and infrastructure
 - Flooding
 - Wind Damage
 - Storm Surge
- Power Outages
- Potential increase in service rates for customers

OVERVIEW OF MULTI-SENSOR TECHNOLOGY



CCTV

High Resolution with
Pan & Tilt Capabilities



LASER

Detects Corrosion
and Deformation



SONAR

Detects Debris and
Deformation

RAPID RESPONSE/RECOVERY:

Pump Station Mobile Enclosure



- The enclosure consists of two rooms
 - One sound-attenuated room for the emergency generator
 - Another climate-controlled room for the electrical equipment including controls, alarm systems, variable speed drives and SCADA System
- Electrical and control connections between the enclosure and the pump station and its equipment are made with cables and plugs that can be opened to permit removal of the enclosure and transport it to a safe location.

Climate Resilience Evaluation & Awareness Tool

CREAT

When selecting a resiliency option, SMRSA recognized that there is a need for:

1

Long-term climate conditions

2

Timing of climate events to prioritize planning

3

Long term planning to protect critical assets in a cost effective manner.


re-sil-i-ence

[re'ziyens]

noun

The capacity to recover quickly from difficulties

Global Temperature Changes (1861-1996)



Climate Resilience Evaluation & Awareness Tool



CASE STUDY

Belmar Pump Station

- CREAT identified potential climate change threats to the pump station based on location:
 - Storm Surge, Flooding
- CREAT provided multiple future climate scenarios


Climate Resilience Evaluation & Awareness Tool

- Performs **BASELINE RISK ASSESSMENT** of the pump station's current resilience to these threats
 - What is the utility's current level of risk for the pump station?
 - DO NOTHING Scenario
- Provides strategies that build resiliency into projected climate changes
 - Populated CREAT with strategies and associated capital costs



Raise

Raise equipment in the building to 4ft above the base flood elevation



Relocate

Rebuild Pump Station outside of flood zone



Rapid Response / Recovery


A mobile enclosure that protects critical pump station components that can be relocated before a storm

- Performs a second assessment: **Resilience Assessment**
 - Risk assuming Raise, Relocate or Rapid Response/Recovery is implemented

Climate Resilience Evaluation & Awareness Tool

CREAT

- CREAT calculates risk reduction based on the difference between baseline conditions and resilience conditions
- The adaptive measures are compared and prioritized on the basis of risk reduction and cost.



\$4.4 M \$1.9 M

Mobile Enclosure Version 2.0: Pitney Avenue Pump Station

Adaptive Measures

- Mobile Pump Station
- All electrical equipment above 500 year flood elevations

Cost: \$1.6 Million | Risk Reduction Units: 101



BEFORE



AFTER

Mobile Enclosure Version 3.0: Belmar Pump Station

Adaptive Measures

- Mobile Pump Station
- All electrical equipment above 500 year flood elevations
- Submersible Pumps

Cost: \$1.6 Million

Risk Reduction Units: 101.4



BEFORE

AFTER

Lake Como Pump Station

Adaptive Measures

- Relocate building
- Extend force main and sewer line

Cost: \$3.2 Million

Risk Reduction Units: 145



BEFORE



AFTER

Penn Avenue Pump Station

Adaptive Measures

- RAISE
- All electrical equipment raised 4 feet above 500 year flood elevation

Cost: \$2.4 Million

Risk Reduction Units: 54




BEFORE



AFTER

SMRSA's Regional Resiliency Plan



Funding for a Climate Readiness Program

Internal Funding Mechanisms:

1

Dedicated, set aside fund for:

- Disaster funding
- Climate Readiness
- Asset Management

2

Funding for set aside funds is accumulated through an annual rate increase


- 2-3 percent annually
- Rate stabilization
- Predicable, reasonable, necessary strategy

3

Implement capital improvements with a high potential for resiliency



South Monmouth Regional Sewerage Authority
Sewer Use Charge History
with 2016 & 2017 Projection





Mobile Enclosure Version 3.0: Belmar Pump Station

FUNDING:

- State funded
- NJEIT
- SAIL Program
- 19% Principal Forgiveness Loans
- Authority Reserves



Lake Como Pump Station

FUNDING: – 90% FEMA
– Authority Reserves
– NJEIT
– SAIL Program



Penn Avenue Pump Station

FUNDING: 100% Authority Reserves

Always tell your story...



Financial Strategies

- Consistent, persistent dialogue with state and federal agencies
- Be prepared to support your proposal with data
- Transparency with customers

Climate Change Readiness for the Wastewater Treatment Plant Cogeneration System




GAS CONDITIONING SYSTEM :
REMOVES WATER, HYDROGEN SULFIDE,
SILOXANES

**INTERNAL
COMBUSTION ENGINES**

Cogeneration: WWTP Emergency Response Plan

When there is a power outage...

- The cogeneration system produces approximately 42-52% of the electricity
- Auxiliary Generators provide the balance
 - 1,200 kW Primary Generator
 - 500 kW Secondary Generator



COGENERATION

Future Operations

Normal Operation:

- Cogen system provides about 60% of the plant's energy
 - Utilize 270 kW Dual Fuel Engine
- Authority will purchase 40% of remaining required energy

During a Power Outage:

- Cogen system provides about 100% of the plant's energy
 - The plant becomes a "Island"
 - Utilize 270 kW Dual Fuel Engine
 - Utilize the two 160 kW Dual Fuel Engines
- Utilize auxiliary generators

Funded by New Jersey Energy Resiliency Bank

- Total Project Cost : \$3,390,000
- Total Grant Portion: \$2,847,674
- Loan Portion: \$1,070,326